NSF International, an independent, not-for-profit, nongovernmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

NOT FOR DISTRIBUTION OR SALE

This Standard is subject to revision.

Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Wastewater Technology c/o NSF International 789 North Dixboro Road, PO Box 130140 Ann Arbor, Michigan 48113-0140 USA

NSF International Standard / American National Standard for Wastewater Technology ±

Glossary of Wastewater Technology Terminology

DISTRIBUTION OR SALE

Standard Developer NSF International

Designated as an ANSI Standard September 6, 2021

i

Prepared by
The NSF Joint Committee on Wastewater Technology

Recommended for adoption by

Disclaimers 1

NSF International (NSF), in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this standard. It is the responsibility of the user of this standard to judge the suitability of the ANS IRU WKH XVHU¶V purpose.

This page is intentionally left blank. ORSALE

This page is intentionally left blank. ORSALE

Foreword ²

The purpose of this glossary is to provide a single resource containing all of the technical terms used in all NSF Wastewater Technology Standards. With all NSF Wastewater Technology definitions located in one document, and not in the individual Wastewater Technology s

NOTFOR DISTRIBUTED IN THE STATE OF THE STATE

© 2021 NSF NSF/ANSI 437 ±2021

3 Definitions

3.1 30-day (30-d) average: The average of daily measurements over a 30-d period, calculated as the sum of all daily measurements taken during a 30-d period divided by the number of daily measurements taken during that 30-d period.

- 3.2 30-day (30-d) geometric mean (geo mean) : A type of average, calculated as the nth root of the product of n values (daily measurements) taken over a 30-d period.
- 3.3 7-day (7-d) average: The average of daily measurements over a 7-d period, calculated as the sum

© 2021 NSF NSF/ANSI 437 ±2021

food processing is involved, and laundering facilities for hospitals, hotels, rental uniforms, and other facilities likely to handle high amounts of soiling, or high-strength commercial cleaners. Wastewater (including greywater) from commercial facilities may exhibit moderately high concentrations of biochemical oxygen demand, chemical oxygen demand, total suspended solids and salts. Commercial facilities do not include multifamily residential applications.

- 3.18 commercial wastewater treatment system : An organized and coordinated system of components that functions to treat all wastewater generated by a commercial facility.
- 3.19 contact chamber: The tank or compartment that provides mixing and retention time for disinfection

© 2021 NSF NSF/ANSI 437 ±2021

3.51 pump dependent chlorine disinfection device : A chlorine disinfection device that relies on the operation of a pump to control the amount of chlorine delivered to the contact tank.

- 3.52 quality assurance project plan (QAPP) : A written document that describes the implementation of quality assurance and quality control (QA/QC) activities during the life cycle of the project.
- 3.53 rated daily hydraulic capacity : The rated flow measured in liters per day (LPD) (gallons per day [GPD]) as defined by the manufacturer.
- 3.54 residential: Single-family dwellings, occupied on a year-round basis.
- 3.55 residential laundry facilities : Laundering for residences, and businesses that launder residential type laundry such as coin-operated facilities.
- 3.56 residential wastewater: Human body waste and liquid waste generated by the occupants of an

This page is intentionally left blank. ORSALE

Std. #	Standard title
184	Residential Dishwashers
223	Conformity Assessment Requirements for Certification Bodies that Certify Products Pursuant to NSF/ANSI/CAN 60: Drinking Water Treatment Chemicals ±Health Effects
244	Drinking Water Treatment Units Supplemental Microbiological Water Treatment Systems ±Filtration
245	Wastewater Treatment Systems ±Nitrogen Reduction
305	Personal Care Products Containing Organic Ingredients
321	Goldenseal Root (Hydrastis canadensis)
330	Glossary of Drinking Water Treatment Unit Terminology
332	Sustainability Assessment for Resilient Floor Coverings
336	Sustainability Assessment for Commercial Furnishings Fabric
342	Sustainability Assessment for Wallcovering Products
347	Sustainability Assessment for Single-Ply Roofing Membranes
350	Onsite Residential and Commercial Water Reuse Treatment Systems
350-1	Onsite Residential and Commercial Greywater Treatment Systems for Subsurface Discharge
358-1	•

